



## Florida Department of Transportation

RON DESANTIS  
GOVERNOR

605 Suwannee Street  
Tallahassee, FL 32399-0450

JARED W. PERDUE, P.E.  
SECRETARY

March 20, 2026

### ADDENDUM NO. 2

TO: PROSPECTIVE BIDDERS AND PLAN HOLDERS

**PROPOSAL/CONTRACT ID: T1915**

**FINANCIAL PROJECT NUMBER(S): 450723 1 52 01, 450723 1 52 02, 450723 1 52 03 and  
450723 1 52 04**

**FEDERAL AID PROJECT NUMBER(S): D126009B**

**COUNTY(IES): Lee**

**PROJECT NAME(S): SR 78, From W of Santa Barbara Blvd. To E of Del Prado Blvd.**

---

**BIDS TO BE RECEIVED: March 25, 2026**

### PLANS REVISION

Plan sheets of the subject project have been revised. Please go to the Online Ordering Web Site at <https://fdotwp1.dot.state.fl.us/contractproposalprocessingonlineordering> to download the Plans Revision from your Order History. Please substitute these sheets for the like-numbered sheets in the Plans you now have.

### AMENDMENT NOTIFICATION

If you are a BID DOCUMENT HOLDER for the subject project, please go to the Online Ordering Web Site at <https://cpp.fdot.gov> to download Amendment File for this Bid Document.

If you are a BID DOCUMENT HOLDER, please acknowledge receipt of this Addendum in AASHTOWare Project Bids by opening the Acceptance of Bidding Acknowledgements folder and confirming your acknowledgement of Amendment and Addenda files. Failure to load all amendment files will cause the bid to be rejected.

Sincerely,

*A Mirza Rezazadeh*

A Mirza Rezazadeh, Manager  
Contracts Administration Office

AR:rs  
Attached

DATE: 3/19/26 1 of 3  
 TO: Final Plans(CO-FINALPLANS)  
 FROM: Richard J Arico, Project Manager  
 COPIES: DDE, DCPME  
 SUBJECT: **Revision Number 02** - Letting (mo./yr.) 03/26  
 Financial Project ID 450723-1-52-01 (Lead number only)  
 Proposal/Contract ID T1915  
 Federal Funds: No Yes Federal Aid No. D126-009-B  
 County Lee State Road No. 78

Mandatory Only: No Yes (\*If Yes, Signatures Not Required.)

I have reviewed for effects on the Specifications Package and a package revision is   
 is not  required. \*Approved By: *Lavonia Poole* Date: 03/19/2026 | 12:58 PM EDT  
DocuSigned by: Lavonia Poole  
 94CE033C7AD64D0  
 Signature of District Specifications Engineer

\*Concurred by: Via attached email Date: 3/19/2026  
Signature of Director of Transportation Development or Designee

If Projects of Division Interest,

\*Authorized By: \_\_\_\_\_ Date: \_\_\_\_\_  
Print Name of FHWA Engineer

REVISIONS RECEIVED IN THE FINAL PLANS OFFICE WITHIN 15 WORK DAYS OF THE LETTING MUST BE APPROVED BY THE DISTRICT SECRETARY.

NO REVISIONS ALLOWED WITHIN 5 WORK DAYS OF THE LETTING WITHOUT APPROVAL.

\*Approved By: Via attached email Date: 3/19/2026  
Signature of District Secretary

SUPPLEMENTAL SPECIFICATIONS PACKAGE NUMBER \_\_\_\_\_ (\_\_\_\_ Pages).

REISSUED SPECIFICATIONS PACKAGE \_\_\_\_\_ (\_\_\_\_ Pages).

PLANS REVISION NUMBER 02 (116 Sheets):

CONTRACT TIME REVISED: No Yes(if yes, 250 Total Calendar Days)

---



**Summary of Quantities (Trns\*port)**3 of 3

<b>Pay Item</b>	<b>Sheet No.</b>	<b>Add. / Del. / Rev.</b>	<b>Old Quantity</b>	<b>New Quantity</b>
0102 1	4	Revision/SEQ 01	1/225	1/250
0102 5	4	Revision/SEQ 01	3456	3960
0102 14	4	Revision/SEQ 01	544	605
0102 60	4	Revision/SEQ 01	7268	8209
0102 74 1	4	Revision/SEQ 01	36829	41565
0102 74 8	6	Revision/SEQ 01	501	605
0102 76	4	Revision/SEQ 01	338	382
0102 99	4	Revision/SEQ 01	1291	1453
0102104	7	Revision/SEQ 01	900	1000
0102107 1	7	Revision/SEQ 01	900	1000
0102115	4	Revision/SEQ 01	522	588
0102150 1	4	Revision/SEQ 01	374	416
0102150 2	4	Revision/SEQ 01	374	416
0107 1	13	Revision/SEQ 01	326.73	367.56
0107 2	13	Revision/SEQ 01	324.41	364.95
0107 1	15	Revision/SEQ 02	87.59	98.55
0107 2	15	Revision/SEQ 02	52.44	59.00
0107 1	16	Revision/SEQ 03	0.74	0.83
0107 2	16	Revision/SEQ 03	0.70	0.79
0327 70 6	26	Revision/SEQ 01	73306	108611
0334 1 13	33	Revision/SEQ 03	218.3	224.7
0337 7 83	29	Revision/SEQ 01	6355.4	9268.1
0337 7 83	33	Delete/SEQ 03	19.9	0

## Barker, Michelle

---

**From:** Mills, Nicole  
**Sent:** Wednesday, March 18, 2026 11:26 AM  
**To:** Barker, Michelle  
**Cc:** Alejos, Amanda; Schley, Casey  
**Subject:** RE: ACTION NEEDED: 450723-1 Revision Request Prior to Letting  
**Attachments:** ACTION NEEDED: 450723-1 Revision Request Prior to Letting

Approved at all levels. Please proceed with processing the revision.

**Nicole E. Mills, P.E.**  
**Director of Transportation Development**  
Florida Department of Transportation, District One  
801 North Broadway Ave.  
Bartow, Florida 33830  
(863) 519-2808 – Desk  
(863) 698-6526 – Cell



---

**From:** Barker, Michelle <Michelle.Barker@dot.state.fl.us>  
**Sent:** Wednesday, March 18, 2026 11:23 AM  
**To:** Mills, Nicole <Nicole.Mills@dot.state.fl.us>  
**Cc:** Alejos, Amanda <Amanda.Alejos@dot.state.fl.us>; Schley, Casey <Casey.Schley@dot.state.fl.us>  
**Subject:** ACTION NEEDED: 450723-1 Revision Request Prior to Letting  
**Importance:** High

Good morning Nicole.

In-lieu of Docusign, I am requesting Director and Secretary approval to process a revision on this project via email. Revision committee has concurred with the processing of these revisions.

I have attached the delegation letter for Secretary Driggers.

*Thank you!*

*Have a great day!* 😊

*Michelle Barker*

Specifications Coordinator  
D1 Program Management  
Phone: 863-519-2594  
Email: [Michelle.Barker@dot.state.fl.us](mailto:Michelle.Barker@dot.state.fl.us)



*Florida Department of Transportation*

RON DESANTIS  
GOVERNOR

801 North Broadway  
Bartow, Florida 33830

JARED W. PERDUE, P.E.  
SECRETARY

**MEMORANDUM**

DATE: June 17, 2025

TO: Lori Albritton, Transportation Support Manager  
Nicole E. Mills, P.E., Director of Transportation Development  
John M. Kubler, P.E., Director of Transportation Operations

FROM: James M. Driggers, Jr., P.E., Interim District Secretary

COPIES: Legal Office, Human Resources Office, Financial Services

SUBJECT: Delegation of Authority

---

You are delegated signature and approval authority anytime during my absence from the office. Signatures should be made in your name for the District Secretary.

This delegation will remain in effect from June 17, 2025 – June 16, 2026.

JD:jm

  
\_\_\_\_\_  
James M. Driggers, Jr., P.E.  
Interim District Secretary

6-17-25  
\_\_\_\_\_  
Date

## **Barker, Michelle**

---

**From:** Potter, Will  
**Sent:** Wednesday, March 18, 2026 5:25 PM  
**To:** Ingle, Kevin  
**Cc:** Schley, Casey; Barker, Michelle; Agacinski, David; Setchell, Amy; Clayton, Benjamin  
**Subject:** RE: RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188 Published

Approved.

Will Potter  
Director, Office of Design  
850-414-4267

---

**From:** Ingle, Kevin <Kevin.Ingle@dot.state.fl.us>  
**Sent:** Wednesday, March 18, 2026 10:50 AM  
**To:** Potter, Will <William.Potter@dot.state.fl.us>  
**Cc:** Schley, Casey <Casey.Schley@dot.state.fl.us>; Barker, Michelle <Michelle.Barker@dot.state.fl.us>; Agacinski, David <David.Agacinski@dot.state.fl.us>; Setchell, Amy <Amy.Setchell@dot.state.fl.us>; Clayton, Benjamin <Benjamin.Clayton@dot.state.fl.us>  
**Subject:** RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188 Published

Good morning Will,

A Prebid question came in for Proposal T1915 FPID 45072315201 that will require a revision per the EOR. This is within the 5 day window and needs your approval.

See question and response below:

**Question:**

- The typical section for Andalusia Blv does not show any FC 12.5; however, the Estimated Quantities sheet includes a total of 19.9 tons of FC 12.5.  
Could you please confirm where this FC 12.5 quantity is coming from?
- Could you please confirm if the 1.5 inch milling quantity shown in the plans is correct?  
We are seeing approximately a 34,000 SY difference in our takeoff compared to the estimated quantities.
- We are also seeing an approximate 3,000 ton difference in FC quantities between our takeoff and the estimated quantities  
Could you please confirm if the FC quantities are correct?

**Response from EOR:**

It appears the quantity busts are valid. We will have changes in quantities. However, there are no plan updates required.

Please let us know if you concur with the processing of this revision.

Thanks,

Kevin S. Ingle, P.E.  
District Design Engineer  
FDOT, District One  
801 North Broadway Avenue  
Bartow, FL 33830  
(863) 519-2740  
(863) 272-4366 Cell

**Barker, Michelle**

---

**From:** Potter, Will  
**Sent:** Thursday, March 19, 2026 9:43 AM  
**To:** Ingle, Kevin  
**Cc:** Schley, Casey; Barker, Michelle; Agacinski, David; Setchell, Amy; Clayton, Benjamin  
**Subject:** RE: RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188  
Published

I concur.

Will Potter  
Director, Office of Design  
850-414-4267

---

**From:** Ingle, Kevin <Kevin.Ingle@dot.state.fl.us>  
**Sent:** Thursday, March 19, 2026 7:44 AM  
**To:** Potter, Will <William.Potter@dot.state.fl.us>  
**Cc:** Schley, Casey <Casey.Schley@dot.state.fl.us>; Barker, Michelle <Michelle.Barker@dot.state.fl.us>; Agacinski, David <David.Agacinski@dot.state.fl.us>; Setchell, Amy <Amy.Setchell@dot.state.fl.us>; Clayton, Benjamin <Benjamin.Clayton@dot.state.fl.us>  
**Subject:** RE: RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188 Published

Will, an additional question regarding the contract time due to this quantity bust came in, which will require us to revise the contract time.

See question and response in below.

The answer to this question will be posted after Revision #2, Addendum #2 has been processed. The contract time will change due to additional milling and tonnage of asphalt. This answer will be posted to the State Prebid website after Addendum # 2 has been issued to all prospective bidders.

**Question:** With regard to question 53188: Can the Department also grant additional contract time to complete the overrun of pay items referenced?

**Answer:** Please see Revision # 2, Addendum # 2 for the answer to this question. Addendum # 2 was sent out to all prospective bidders on \_\_\_\_\_.

Please let us know if you concur with this revision.

Thanks,

Kevin S. Ingle, P.E.

District Design Engineer  
FDOT, District One  
801 North Broadway Avenue  
Bartow, Fl 33830  
(863) 519-2740  
(863) 272-4366 Cell

---

**From:** Potter, Will <[William.Potter@dot.state.fl.us](mailto:William.Potter@dot.state.fl.us)>  
**Sent:** Wednesday, March 18, 2026 5:25 PM  
**To:** Ingle, Kevin <[Kevin.Ingle@dot.state.fl.us](mailto:Kevin.Ingle@dot.state.fl.us)>  
**Cc:** Schley, Casey <[Casey.Schley@dot.state.fl.us](mailto:Casey.Schley@dot.state.fl.us)>; Barker, Michelle <[Michelle.Barker@dot.state.fl.us](mailto:Michelle.Barker@dot.state.fl.us)>; Agacinski, David <[David.Agacinski@dot.state.fl.us](mailto:David.Agacinski@dot.state.fl.us)>; Setchell, Amy <[Amy.Setchell@dot.state.fl.us](mailto:Amy.Setchell@dot.state.fl.us)>; Clayton, Benjamin <[Benjamin.Clayton@dot.state.fl.us](mailto:Benjamin.Clayton@dot.state.fl.us)>  
**Subject:** RE: RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188 Published

Approved.

Will Potter  
Director, Office of Design  
850-414-4267

---

**From:** Ingle, Kevin <[Kevin.Ingle@dot.state.fl.us](mailto:Kevin.Ingle@dot.state.fl.us)>  
**Sent:** Wednesday, March 18, 2026 10:50 AM  
**To:** Potter, Will <[William.Potter@dot.state.fl.us](mailto:William.Potter@dot.state.fl.us)>  
**Cc:** Schley, Casey <[Casey.Schley@dot.state.fl.us](mailto:Casey.Schley@dot.state.fl.us)>; Barker, Michelle <[Michelle.Barker@dot.state.fl.us](mailto:Michelle.Barker@dot.state.fl.us)>; Agacinski, David <[David.Agacinski@dot.state.fl.us](mailto:David.Agacinski@dot.state.fl.us)>; Setchell, Amy <[Amy.Setchell@dot.state.fl.us](mailto:Amy.Setchell@dot.state.fl.us)>; Clayton, Benjamin <[Benjamin.Clayton@dot.state.fl.us](mailto:Benjamin.Clayton@dot.state.fl.us)>  
**Subject:** RE: ACTION REQUIRED: Proposal T1915 / 45072315201: Question ID 53188 Published

Good morning Will,

A Prebid question came in for Proposal T1915 FPID 45072315201 that will require a revision per the EOR. This is within the 5 day window and needs your approval.

See question and response below:

**Question:**

- The typical section for Andalusia Blv does not show any FC 12.5; however, the Estimated Quantities sheet includes a total of 19.9 tons of FC 12.5.  
Could you please confirm where this FC 12.5 quantity is coming from?
- Could you please confirm if the 1.5 inch milling quantity shown in the plans is correct?  
We are seeing approximately a 34,000 SY difference in our takeoff compared to the estimated quantities.
- We are also seeing an approximate 3,000 ton difference in FC quantities between our takeoff and the estimated quantities  
Could you please confirm if the FC quantities are correct?

**Response from EOR:**

It appears the quantity busts are valid. We will have changes in quantities. However, there are no plan updates required.

Please let us know if you concur with the processing of this revision.

Thanks,

Kevin S. Ingle, P.E.  
District Design Engineer  
FDOT, District One  
801 North Broadway Avenue  
Bartow, FL 33830  
(863) 519-2740  
(863) 272-4366 Cell